

# www.mbsm.pro, Compresseurs, LBP, MBP, HBP , Difference, and, signification

Category: Solutions, Tester ok  
written by Jamila | 9 September 2018

LEARN MORE ABOUT CLASSIFICATION OF COMPRESSORS		
NOMENCLATURE	EVAPORATION TEMPERATURE	APPLICATION EXAMPLES
LBP	-35°C to -10°C	Household refrigerators, freezers, island freezers
L/MBP	-35°C to -5°C	Commercial counters, beverage displays, some water coolers, ice cube machine, some wine coolers, vending machines
HBP	-5°C to +15°C	Dehumidifiers, coolers, some water coolers, some wine coolers

PictureS Mbsm Dot Pro : [www.mbsm.pro](http://www.mbsm.pro)

le B correspond à back il faut le traduire en contre pression , en fait sur les compresseurs frigorifiques du fait du circuit fermé , il y a une delta P entre entrée et sortie du compresseur , ce n'est pas comme un compresseur classique d'air comprimé